

COMMITTEE ON LEGISLATIVE RESEARCH
OVERSIGHT DIVISION

FISCAL NOTE

L.R. No.: 0942-01

Type: Original

Bill No.: HB 386

Date: January 23, 2017

Subject: Utilities

Bill Summary: This proposal establishes a minimum clearance for high voltage direct current lines above 470 kV to 50 feet above land and 55 feet above water.

State Fiscal Highlights

- No direct fiscal impact on the state is anticipated.

Local Fiscal Highlights


- No direct fiscal impact on local political subdivisions is anticipated.

Fiscal Analysis

Officials from the **Department of Economic Development (Public Service Commission, the Office of Public Counsel and the Division of Energy)** and the **Metropolitan St. Louis Sewer District**) each assume the proposal will have no fiscal impact on their respective organizations.

Officials from the **Joint Committee on Administrative Rules** state this legislation is not anticipated to cause a fiscal impact beyond its current appropriation.

Utility companies required to replace current lines may be fiscally impacted as a result of this proposal. Also, this legislation is not federally mandated, would not duplicate any other program and would not require additional capital improvements or rental space.



Mickey Wilson, CPA
Director
January 23, 2017

Ross Strobe
Assistant Director
January 23, 2017

